

1. Can the chargers be wall-mounted, or should pedestals be required?
 - a. We will need one dual pedestal and one dual wall mount on day one.

2. Should the response include all necessary electrical infrastructure and upgrades, or just installation at the location on conduit and wire provided?
 - a. Base proposals should include EV charging equipment to be installed where the existing conduit and wire are provided for the four initial parking spaces. The consultant's proposal for any additional EV chargers may include the necessary electrical infrastructure and upgrades or may present a range of options for the DMA to consider.

3. Are there any specific standards that must be considered for the accessibility spaces?
 - a. The chargers must meet accessibility standards at the accessible spaces, relating to the location of operable parts within the max reach.